

What causes my alarm to sound?

Aquaklear systems 2000-2004:

Things to check:

1. A loss of power to the alarm panel. Check Power and restore.
2. A flooded tank due to sludge buildup. Call our offices to schedule tank pump out.
3. A flooded tank due to obstruction in discharge. Pull and clean chlorinator stick (when applicable) and check discharge point to make sure it is not covered over with dirt or debris.
4. **MAKE SURE AIR PUMP IS RUNNING, AND MAKING AIR. ALARM WILL NOT SOUND ON THIS MODEL FOR A PUMP FAILURE! IF IT IS NOT RUNNING, CALL OUR OFFICES FOR SERVICE VISIT.**

Aquaklear systems 2004-present

Things to check:

1. Make sure air hoses at the compressor are not crimped, obstructed or broken. This includes the vinyl hose attached to the side of the pump. (a total of 3 hoses.) Repair any crimps or broken places, as this will actuate the alarm.
2. Check vinyl hose at the alarm panel. It should be plugged in. If it is disconnected, reconnect it.

ALARM MAY BE CAUSED BY FAILED COMPRESSOR. MAKE SURE THAT THE AIR COMPRESSOR IS RUNNING AND MAKING AIR. IF IT IS NOT, CALL OUR OFFICES FOR SERVICE VISIT.

3. A flooded tank due to sludge buildup. Call our offices to schedule tank pump out.
4. A flooded tank due to obstruction in discharge. Pull and clean chlorinator stick (when applicable) and check discharge point to make sure it is not covered over with dirt and debris.
5. Call our offices to schedule service visit

Some systems required lift stations. If your system has a lift station, check to see if tank is flooded over the pump. **THIS REQUIRES IMMEDIATE ATTENTION, IF IT IS FLOODED. CONTACT OUR OFFICES FOR SERVICE VISIT.**